



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **14262-049-02**

Valid from: 2021 06 03  
until: 2023 06 03

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **ETI Elektroelement d.o.o.**  
Obrezija 5  
1411 Izlake  
Slovenia

Product: **Low-voltage fuse links**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s): **SGP-10364/NH00/500V/gG/OVE/C1**

**Österreichischer Verband für Elektrotechnik**  
Head of OVE Certification

*T. Neumayer*  
Digitally signed by T. Neumayer  
Email=t.neumayer@ove.at



Wien, 2021 05 20

Dipl.-Ing. T. Neumayer

## OVE Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).



**Manufacturer:**

ETI Elektroelement d.o.o.  
Obrezija 5  
1411 Izlake  
Slovenia

**Factory location(s):**

ETI Elektroelement d.o.o.  
Obrezija 5  
1411 Izlake  
Slovenia

ETI Polam Sp. z.o.o.  
ul. Jana Pawla II 18  
06-100 Pultusk  
Poland

**Tested and certified according to:**

ÖVE/ÖNORM EN 60269-1:2015-06-01  
ÖVE/ÖNORM E 8669-2:2014-11-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity of the certified product(s) with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**. For the presumption of conformity according to Art. 12 with the safety objectives according to Art. 3 of the Directive, transitional periods given in the Official Journal of the European Union have to be observed.

**Product: Low-voltage fuse links**

**Type designation:**

**Rating:**

**Trademark:**

**NH00 / NV00**  
Rated voltage: AC 500 V  
Rated current: 6 A  
120 kA  
gG

ETI

**NH00 / NV00**  
Rated voltage: AC 500 V  
Rated current: 10 A  
120 kA  
gG

ETI

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 16 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 20 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 25 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 32 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 35 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 40 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 50 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 63 A  
120 kA  
gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V  
Rated current: 80 A  
120 kA  
gG

ETI

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**NH00 / NV00**

Rated voltage: AC 500 V

Rated current: 100 A

120 kA

gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V

Rated current: 125 A

120 kA

gG

ETI

**NH00 / NV00**

Rated voltage: AC 500 V

Rated current: 160 A

120 kA

gG

ETI

---

**OVE Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).